

Certificate

No. 1435.IM.152939/20 V1.0

TÜV NORD Systems GmbH & Co. KG hereby certifies

ASTAVA B.V.
Industrieweg 30
7944 HS Meppel, Netherlands

that the

Interlocking Manifold, Type 1001 with Ball Needle Ball – Function

with the safety function “Operating Steps and Availability” for maintenance of pressure sensors is capable for safety related applications up to SIL 3 and meets the requirements listed in the below mentioned standard

- IEC 61508: 2010 part 1 and part 2

Certification program Leittechnik (SEB-ZE-SEECERT-VA-320-20, Rev. 5.1 / 04.19)

This certificate considers only maintenance and does not consider the usage of the system in safety instrumented systems with SIL classification.

**Base of certification is the report
1435.IM.152939/20TB in the valid
version.**

**This certificate entitles the holder to
use the pictured safety approved mark.**

**Valid until: 2026-01-29
File reference: 8118102000**

Hamburg, 2021-01-28


Bianca Puff

